

ADDENDUM NUMBER 2:
Bid #14-14
High/Hanover Parking Facility Interior Painting
Bid Proposal
September 12, 2013

This Addendum forms part of the original document marked: High/Hanover Parking Facility Interior Painting Bid #14-14.

The following questions have been asked and answered:

1. **Q:** Can we get the painting scheme picture?
A: It is attached.

2. **Q:** How many stair flights will need painting after the stairwell repair project is over?
A: Some of the steel undersides of the stair well landings, and some of the steel undersides of the stair flights will require painting (from red to blue). These are the quantities of those areas:

Tower	# platforms to paint	# flights to paint
Fleet	Two (2)	Six (6)
Ladd	All six (6)	One (1) plus a partial flight
Elevator/High	None	Four (4)
Hanover	None	Two (2)

Where steel is now painted red, it is to be painted blue. Do not paint unpainted concrete or unpainted galvanized metal. Some of these surfaces are rusty and will require rust removal before painting.

3. **Q:** Can we have the plans for the garage?
A: Contact Jamie McCarthy at 603-766-1410. He can send you the plans you need.

Also, included as part of this addendum is the pre-bid sign in sheet, and the painting scheme picture as referenced in question 1. **See the following pages.**

Please acknowledge this addendum within your proposal, failure to do so may subject a bidder to disqualification.

End of Addendum #2



PMS 647



PMS 5575



PMS 7527

Color System 1

Garage Stairwell Painting Pre-Bid Meeting -- 9/9/13

Sign-In Sheet

NAME	FIRM	PHONE	EMAIL
Jeff Bunnap	Associated Concrete Coating Inc	603-669-2780	Jeff@concoat.com
Lou Carrivari	CPI	603-659-2708	Lou@carriarivari.com
Scott Smith	Clarke Painting	207-233-8581	clarkepaint@cof.com