

ADDENDUM NUMBER 4:  
Portsmouth City Hall Boiler Replacement 2013  
Bid Proposal #36-13

Issued: May 29, 2013

This Addendum forms part of the original document marked: **Portsmouth City Hall Boiler Replacement 2013 Bid Proposal #36-13**

**A. Bidding Requirements:**

1. **The bid due date has been changed to May 31, 2013 @ 10:00 a.m.**

**B. Bidder's Questions: The following questions have been asked and answered.**

Question #1 Can you please clarify the Control Items for Boiler Pumps 1-4 (BP1-4):  
Sheet E2, Schedule of Mechanical Equipment, Note 16, calls for duplex motor controllers with alternation. Sheet H102, Pump Schedule, Note 2, calls for a different item. Are these controllers provided with the Package?

Answer #1 **The following information answers and/or supersedes the original bid documents:**  
Drawing E-2:  
Schedule of Mechanical Equipment: Change boiler pump voltages on BP-1, BP-2, BP-3 and BP-4 from 208V, 3 Phase to 230V, Single Phase. Change "Electrical Work Required" notes from "1, 3 & 16" to "1, 3, 5 & 15" for BP-1, BP-2, BP-3 and BP-4.

Drawing E-4:  
Change branch circuit for boiler pumps BP-1 through BP-4 from "3#12 & #12G-3/4"C, 15A-3P C/B" to "2#12 & #12G-3/4"C, 20A-2P C/B". Add a 30A-2P safety switch at each boiler pump.

Drawing E-5:  
Panel schedule PP2: Change boiler pump circuit breakers from "15A-3P" to "20A-2P" for BP-1 through BP-4.

All else remains unchanged from original bid document.

Please acknowledge receipt of this addendum within your proposal, failure to do so may subject a bidder to disqualification.

**End of Addendum #4**