

Portsmouth, New Hampshire
School Department

Bid #60-14

Sherburne School and High School Roofs Replacement
Addendum 2
June 16, 2014

This Addendum forms part of the original document marked: Bid #60-14 Sherburne School and High School Roofs Replacement.

The bid opening date and time have been changed to: **Thursday June 19, 2014 @ 2:00 p.m.**

- A) The contractors requested that the lump sum be separated by each location.

Replace pages 8 and 9 of the original bid document with the attached pages 8 and 9.

- B) Under Section: Sherburne School Roof Replacement and the High School Roof Replacement, section 2.2 Roof Insulation – **the thickness has been changed to 3.5 inches.**

2.2 ROOF INSULATION

- A. **ASTM C 578, Type II Polyisocyanurate Board Insulation minimum of a PSI 20**

Insulation Thickness to 3.5 inches

- C) Under Section: Sherburne School Roof Replacement and the High School Roof Replacement, Section 3.1 Installation of EPDM Roofing paragraph B:

- **Add: Installation of insulation to tectum decking will be either by cold adhesive or spray foam application per manufactures specifications.**

3.1 INSTALLATION OF EPDM ROOFING

- B. Mechanically fasten each layer of insulation to deck as per manufacture's fastening requirements:

ADD:

Installation of insulation to tectum decking will be either by cold adhesive or spray foam application per manufactures specifications.

- D) Under Section: Sherburne School Roof Replacement and the High School Roof Replacement, Section 3.1 Installation of EPDM Roofing:

Add the following paragraphs H and I.

H. Contractor will remove abandoned curves, fill in with roof decking, and seal to existing roof thickness.

I. Contractor is responsible to verify deck slope to ensure proper drainage to roof drains or run off.

All else will remain unchanged from the original bid document.

Please acknowledge this addendum within your proposal, failure to do so may subject a bidder to disqualification.

End of Addendum 2

(Continue below for replacement pages 8 and 9 referenced above)

PROPOSAL FORM

Sherburne School and High School Roofs Replacement

CITY OF PORTSMOUTH, N.H.

To the City of Portsmouth, New Hampshire, herein called the Owner.

The undersigned, as Bidder, herein referred to as singular and masculine declares as follows:

1. All interested in the Bid as Principals are named herein.
2. This bid is not made jointly, or in conjunction, cooperation or collusion with any other person, firm, corporation, or other legal entity;
3. No officer, agent or employee of the Owner is directly or indirectly interested in this Bid.
4. The bidder has carefully examined the sites of the proposed work and fully informed and satisfied himself as to the conditions there existing, the character and requirements of the proposed work, the difficulties attendant upon its execution and the accuracy of all estimated quantities stated in this Bid, and the bidder has carefully read and examined the Drawings, Agreement, Specifications and other Contract Documents therein referred to and knows and understands the terms and provisions thereof;
5. The bidder understands that the quantities of work calculated in the Bid or indicated on the Drawings or in the Specifications or other Contract Documents are approximate and are subject to increase or decrease or deletion as deemed necessary by the Portsmouth City Engineer. Any such changes will not result in or be justification for any penalty or increase in contract prices; and agrees that, if the Bid is accepted the bidder will contract with the Owner, as provided in the Contract Documents, this Bid Form being part of said Contract Documents, and that the bidder will supply or perform all labor, services, plant, machinery, apparatus, appliances, tools, supplies and all other activities required by the Contract Documents in the manner and within the time therein set forth, and that the bidder will take in full payment therefor the following item prices, to wit:

BASE BID

The undersigned agrees to complete the work for the total Base Bid Price of

ITEM #	EST. QTY.	ITEM DESCRIPTION & LUMP SUM PRICE IN WORDS	LUMP SUM PRICE IN FIGURES
1	LS	Sherburne School	_____
		High school Roof #1 Auditorium	_____
		Lump sum Total	_____

The base bid shall serve as the basis of award.

Bid Alternate #1: High School Roof #2 See Map \$ _____

Bid Alternate #2: High School Roof #3. See Map \$ _____

Bid Alternate #3: High School Roof #4. See Map \$ _____

Bid Alternate #4: High School Roof #4. See Map \$ _____

Bid Alternate #5: High School Roof #5. See Map \$ _____

Bid Alternate #6: High School Roof #6. See Map \$ _____

Bid Alternate #7: High School Roof #7. See Map \$ _____

Unit price for per Square Foot for wood facis replacement;

(in figures) \$ _____

(in words) \$ _____

Unit price for per sheet of pylwood replacement;

(in figures) \$ _____

(in words) \$ _____

(Base Bid includes all disposal cost. Bid amounts are to be in both words and figures, in case of error, amount in words shall govern.

The City of Portsmouth reserves the right to reject any and all bids or portions of any and all bids.

To Bidder: It is the intention of this contract that the items listed above describe completely and thoroughly the entirety of the work as shown on the plans and as described in the specifications. All other items required to accomplish the above items are considered to be subsidiary work, unless shown as a pay item.

The Bidder has received and acknowledged Addenda No. _____ Through _____

All Bids are to be submitted on this form and in a sealed envelope, plainly marked on the outside with the Bidder's name and address and the Project name as it appears at the top of the Proposal Form.

_____ Date _____ Company

By: _____ Business Address
Print Name

By: _____ City, State, Zip Code
Signature

Title: _____

Telephone: _____

Email Address: _____